



TC-12118  
Telephone:0484-2632576  
email-qcdiluvva@gmail.com

**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB,ALUVA -683101**  
**WATER TEST REPORT**

ULR NO:TC121192600000088F

Report No: KWA/QCDL-ALY/S/88/04/26-27

Report Issue Date: 18.04.2026

Customer Name & Address  Al Ameen Public School Sreemoolanagaram	Date of Receipt of Payment	28.03.26
	Date of Sample received	07.04.26
	Sample given by	III, FHC Chowara
	Sample Code	ALY/S/88/04/26-27
	Sample Name	Drinking Water
	Sample Condition	Fit For Analysis
	Source of Sample	Well
	Sample Quantity	2 Litre
Test performing dates : From :08.04.26 to 10.04.26		

S/LN	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part 10)-2023 Nephelometric method	1.0	0.72
2	pH at 25°C	-	IS 3025 (Part 11)-2022 Electrometric method	6.5 to 8.5	6.54
3	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2023) EDTA titration method	200	20
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019) Argentometric titration	250	15.50
5	Iron (as Fe)	mg/L	IS 3025 (Part 53) - 2024 1,10 phenanthroline method	1	0.18
6	Nitrate (as NO3)	mg/L	APHA 24th Edition-4500-NO3 Method B(UV Spectrophotometric Screening Method)	45	2.11
7	Electrical conductivity at 25°C	micromhos/cm	IS 3025 (Part 14)- 2013 (Reaffirmed 2023) Electrometric method	-	59.00

Remarks: DL : Detectable Limit  
BDL : Below Detectable Limit

- ND:-1) The result stated above related only to the sample(s) submitted for testing by the customer.  
2) The samples retain for 15 days from the end date of analysis  
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Analyzed By

Reviewed By

Authorized By

End of Report



QUALITY MANAGER  
KWA, QUALITY CONTROL DISTRICT LAB  
ERNAKULAM, ALUVA - 683 101

KWA/QCDL/ALY/04/2020	Issue Date : 04.10.2020
Rev.No: 06	Page 1 of 2
Rev.Date : 15/07/2025	



Telephone: 0484-2623576  
email-gcdialuva@gmail.com

**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB, ALUVA - 683101**  
**WATER TEST-BACTERIOLOGY REPORT**

Report No: ALY/B/88

Report Issue Date: 18.04.2026

Customer Name & Address		Date of Receipt of Payment	28.03.26	
Al Ameen Public School Sreemoolanagaram		Date of Sample received	07.04.26	
		Sample given by	HI, FHC Chowara	
		Sample Code	ALY/B/88	
		Sample Name	Drinking Water	
		Sample Condition	Fit For Analysis	
		Source of Sample	Well	
		Sample Quantity	250ml	
		Test performing dates :		From :07.04.26 to 08.04.26
Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent
2	E-Coll	Shall not be Detected/100ml	IS15185-2016 (Reaffirmed 2021)	Absent

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer.  
2) The samples retain for 4 days from the end date of analysis  
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Analyzed By 

Authorized By Quality Manager 

End of Report

KWA/QCD/ALY/03-2020		Issue Date : 04.10.2020	
Rev No: 06	Rev.Date : 15/07/2025	Page 2 of 2	



QUALITY MANAGER  
KWA, QUALITY CONTROL DISTRICT LAB  
ERNAKULAM, ALUVA - 683 101